

Certificate

Nr.: TR-700416-28012020-E

For the (re-) qualification examination of cleanrooms the conformity regarding the requirements of DIN EN ISO 14644:2015

Company:

Lohmann GmbH & Co. KG

Examination date: 28.01.2020
Validity Certificate: 28.01.2021
ISO-class: 8
GMP grade: D
Test location: Lohmann GmbH & Co. KG
Oberhützer Straße 48
42857 Remscheid

Operation status: in operation

DIN EN ISO 14644:2015

The requirements of DIN EN ISO 14644:2015 for permissible particle concentrations of the room air in the cleanliness ISO class 8 were kept faultless at all measuring points under operation status in operation. The clean rooms and clean room areas had differential pressure to the non controlled areas.

EU GMP

The microbiological contamination of the room air and the microbiological contamination of the surfaces in the clean rooms and clean rooms areas were fulfilled faultless at all measuring points the requirements of the EU GMP Guideline Grade D .

Reutlingen, the 07.02.2020

M.Sc. Isabel Matsch
Laboratory management



Dipl.-Ing. Frank Jürgen Matke
Technical direction